

Fire Systems

Honeywell International

12 Clintonville Road

Northford, CT 06472

203-484-7161

203-484-7118 Fax

April 2013

Honeywell Fire Systems BG-10 Series Pull Station Operation

Honeywell Fire Systems has identified an issue that could affect the normal operation of BG-10 series pull stations manufactured from 1992 through 2010 and distributed under multiple brands including ADT, Fire-Lite Alarms, Johnson Control Inc. and NOTIFIER. The majority of the pull stations were manufactured from 1992 through 2000. For a list of potentially affected pull station model numbers and the recommended BG-12 series replacement model numbers, please review the table on page 2. You can find pictures of BG-10 series pull stations examples on page 3.

The issue is related to the seal installed around the alarm switch, which can deteriorate over time preventing the switch from signaling an alarm when the pull station is activated.

All products have a finite service life and while there is no industry standard for replacement intervals for pull stations, mechanical devices are not intended to be in service indefinitely. Replacement of BG-10 series pull stations is highly recommended. This is an opportunity to upgrade your existing BG-10 series pull stations to the newer, more aesthetically pleasing BG-12 series pull stations.

Due to the age of the majority of these pull stations Honeywell Fire Systems recommends the replacement of all BG-10 series pull stations. If the BG-10 series pull stations are not replaced, Honeywell Fire Systems recommends that all installed BG-10 series pull stations be inspected and tested per National Fire Protection Association (NFPA) 72 requirements by a qualified, fire alarm service provider. The service provider should meet the requirements of the local jurisdiction where the pull stations are installed. A qualified service provider will know how to properly perform the testing and inspection, and can disable any notification circuits or off-premise reporting that may activate when performing the inspection.

While there's a high probability that abnormal pull station operation would be identified during the annual testing requirements prescribed by NFPA 72, Honeywell Fire Systems recommends all BG-10 series pull stations be replaced with a new BG-12 series pull stations. If the pull station is not replaced, a new, free of charge, factory provided alarm switch seal should be installed at the next scheduled service interval. In addition to replacing the seal, these pull stations should be inspected for cracking/fracturing of the plastic housing or bending of the pull station back plate. Any pull station showing signs of cracking of the housing or bending of the back plate should be replaced.

For information on BG-10 series inspection and seal replacement procedures to be performed by a qualified fire alarm service provider, please visit www.pullstationsafety.com.

Recommended Substitution Table for BG-10 Series Pull Stations:

ADT BG-10 series Pull Station Model	ADT BG-12 series Pull Station Model
ADT-BG-10LX: Addressable dual-action, key lock	ADT-BG-12LX: Addressable dual-action, key lock
ADT-BGX-101L: Addressable dual-action, key lock	ADT-NBG-12LX: Addressable dual-action, key lock
ADT-BG-10: Conventional dual-action, hex lock	ADT-BG-12L: Conventional dual-action, key lock
ADT-BG-10L: Conventional dual-action, key lock	ADT-BG-12L: Conventional dual-action, key lock
FIRE-LITE BG-10 series Pull Station Model	FIRE-LITE BG-12 series Pull Station Model
BG-10LX: Addressable dual-action, key lock	BG-12LX: Addressable dual-action, key lock
ARA-10: Conventional dual-action agent release with Abort Switch, Release and Normal LEDs, hex lock	BG-12LRA: Conventional dual-action agent release with Abort Switch, Release and Normal LEDs, key lock
BG-10: Conventional dual-action, hex lock	BG-12: Conventional dual-action, hex lock
BG-10A: Conventional dual-action, hex lock, with annunciator contacts	BG-12LA: Conventional dual-action, key lock, with annunciator contacts
BG-10T: Conventional dual-action, hex lock, with key test feature	No direct replacement. Suggest BG-12
BG-10P: Conventional dual-action, hex lock, with pre-signal option	BG-12LPS: Conventional dual-action, key lock, with pre-signal option
BG-10L: Conventional dual-action, key lock	BG-12L: Conventional dual-action, key lock
BG-10LA: Conventional dual-action, key lock, with auxiliary contacts	BG-12LA: Conventional dual-action, key lock, with auxiliary contacts
BG-10WP: Conventional dual-action, outdoor applications	BG-12LOB: Conventional dual-action, outdoor applications
BG-10SP: Conventional dual-action, hex lock, Spanish	BG-12LSP: Conventional dual-action, key lock, Spanish
Johnson Controls Inc. BG-10 Pull Station Model	Johnson Controls Inc. BG-12 Pull Station Model
JBG-10L: Conventional dual-action, hex lock	JBG-12L: Conventional dual-action, hex lock
JBGX-101L: Addressable dual-action, key lock	JBG-12LX: Addressable dual-action, key lock
NOTIFIER NBG-10 series Pull Station Model	NOTIFIER NBG-12 series Pull Station Model
BGX-101L: Addressable dual-action, key lock	NBG-12LX: Addressable dual-action, key lock
NAR-10: Conventional dual-action agent release, hex lock	NBG-12LR: Conventional dual-action agent release. Key lock
N-ARA-10: Conventional dual-action agent release with Abort Switch, Release and Normal LEDs, hex lock	NBG-12LRA: Conventional dual-action agent release with Abort Switch, Release and Normal LEDs, key lock
NBG-10: Conventional dual-action, hex lock	NBG-12: Conventional dual-action, hex lock

NBG-10A: Conventional dual-action, hex lock, with annunciator contacts	NBG-12LA: Conventional dual-action, key lock, with annunciator contacts
NBG-10T: Conventional dual-action, hex lock, with key test feature	No direct replacement. Suggest NBG-12
NBG-10P: Conventional dual-action, hex lock, with pre-signal option	NBG-12LPS: Conventional dual-action, key lock, with pre-signal option
NBG-10L: Conventional dual-action, key lock	NBG-12L: Conventional dual-action, key lock
NBG-10WP: Conventional dual-action, outdoor applications	NBG-12LOB: Conventional dual-action, outdoor applications
NBG-10SP: Conventional dual-action, hex lock, Spanish	NBG-12LSP: Conventional dual-action, key lock, Spanish

To purchase new BG-12 series pull stations to replace BG-10 series pull stations, please contact your local service provider. If you have questions you should visit www.pullstationsafety.com for additional information.



BG-10 series manual pull station, Fire-Lite BG-10 shown



BG-10 series manual pull station, Johnson Controls Inc. JBG-10L shown



BG-10 series manual pull station, NOTIFIER NBG-10 shown